

# Fire-fighting appliances of helicopter landing area

## ■ Summary of Major Amendments

---

Related Rules/Guidance	Effective date
Rules for the Classification of Steel Ships Pt 8	1 January 2020 (The construction date)

---

## ■ Major Amendments

### ○ Reason for Amendments

– Amended requirement for firefighting appliances of helicopter facilities to reflect IMO Res.MSC.404(96)).

### ○ Amendments

– To be provided with foam firefighting appliances which comply with the relevant provisions of chapter 17 of the Fire Safety Systems Code for helicopter landing area. (Ch.11, 101)

– The special requirement for foam fire extinguishing of helicopter decks is to be deleted. In case of having a helideck, foam firefighting appliances which comply with the provisions of the Fire Safety Systems Code. (Ch.11, 401.)

### ○ Impact Analysis

✓ Indication of any impact on and/or contribution to safety, security or environmental protection

: It is contributed to Increase safety due to enhancement of fire fighting appliance for helicopter landing area

✓ Indication of any impact on net and gross scantlings

: N/A