

Additional fire-extinguishing of the boilers protected by fixed water-based local application fire-extinguishing systems

■ Summary of Major Amendments

Related Rules/Guidance	Effective date
Rules Pt 8 Fire Protection and Fire Extinction	2020.1.1. (The date for construction)

■ Major Amendments

○ Reason for Amendments

- Reflected IMO Res.MSC.409(97))

○ Amendments

- If boilers protected by fixed water-based local application fire-extinguishing systems, an approved foam-type extinguisher of at least 135 liters capacity is not required.

○ Impact Analysis

- ✓ Indication of any impact on and/or contribution to safety, security or environmental protection
: N/A
- ✓ Indication of any impact on net and gross scantlings
: N/A