

Fire protection of spaces containing equipment for the fuel preparation

■ Summary of Major Amendments

Related Rules/Guidance	Effective date
Guidance for the Classification of Ships Using Low-flashpoint Fuels	1 July 2019(Date of which contracts for construction)

■ Major Amendments

○ Reason for Amendments

- To reflect IACS UI GF13 (New) due to lack of clarity as to whether requiring structural fire protection only or also means of escape and active fire protection.

○ Amendments

- Fire protection means structural fire protection, not including means of escape.
- Enclosed spaces containing equipment for fuel preparation such as pumps or compressors or other potential ignition sources are to be provided with a fixed fire-extinguishing system complying with the provisions of SOLAS II-2/10.4.1.1 and the FSS Code and taking into account the necessary concentrations / application rate required for extinguishing gas fires.

○ Impact Analysis

- ✓ Indication of any impact on and/or contribution to safety, security or environmental protection
: N/A
- ✓ Indication of any impact on net and gross scantlings
: N/A